

TERMS OF REFERENCE AND TECHNICAL SPECIFICATIONS

FOR THE PROCUREMENT OF AIRCONDITIONING UNITS

FOR NFSTI Camp Vicente Lim

A. GENERAL SPECIFICATIONS

	OFFICE EQUIPMENT	MINIMUM REQUIREMENTS
1	AIRCONDITIONER 28 UNITS	<i>Floor standing (single phase) 3- tonner (230 V), with installation Specifications: Preferably inverter type, high cooling performance, anti- rust design, strong and robust casing materials. Cooling capacity 12.5 KW Power consumption: minimum 4.48 KW, sound level (low)</i>
2	AIRCONDITIONER 2 UNITS	<i>Wall Mounted Split type, 2HP Single Phase 230 V, Remote Controlled with installation Specifications: Inverter type, high cooling performance, anti-rust design, strong and robust casing materials.</i>
3	AIRCONDITIONER 5 UNITS	<i>Wall Mounted Split type, 1 HP Single Phase 230 V, Remote controlled with installation Specification: Inverter type, high cooling performance, anti-rust design, strong and robust casing materials.</i>

B.DELIVERABLES

B.1. WARRANTY

The Air-conditioning units shall be covered by warranty on all parts, components and after sales services for a period of one (1) year after its inspection and acceptance by the Procuring Entity.

B.2 DOCUMENTATION

1. To be included in the Technical Bid Documents

1.1 Brochures showing the specifications of the product being offered.

2. Submission of Warranty Certificate.