

TECHNICAL SPECIFICATIONS
FOR THE PROCUREMENT OF AIRCONDITIONING UNITS FOR PPSC-HO

A. GENERAL SPECIFICATIONS

	Minimum Requirements
OFFICE EQUIPMENT	
AIRCONDITIONER	<p>Floor Standing Type 5-tonner, 3 phase, 380/400V, with pedestal and installation.</p> <p>Specifications : Inverter, high cooling performance, anti-rust design, strong and robust casing materials.</p> <p>Cooling capacity : minimum 7.1kW, power consumption: minimum 2.51kW, sound level (low) .</p>

TERMS OF REFERENCE

A. DELIVERABLES

A.1 DELIVERY PERIOD

Within 60 - 90 days including the installation of the units from the date of Notice to Proceed (NTP)

A.2 WARRANTY

The Air-conditioning units shall be covered by 5 years warranty on compressor, one (1) year on all major parts/ components, and after sales services for a period of one (1) year after its inspection and acceptance by the Procuring Entity.

A.3 DOCUMENTATION

1. To be included in the Technical Bid Documents
 - 1.1 Brochures showing the specifications of the product being offered.
2. Submission of Warranty Certificate.

B. INSPECTION AND TESTS

The Philippine Public Safety College (PPSC) shall have the right to inspect and/or test the goods to confirm conformity with the Contract. The winning bidder shall furnish test equipment, instrumentation, personnel and supplies necessary to perform all testing. PPSC shall be given a five (5) working day notice prior to tests.

D. MAINTENANCE/TECHNICAL SUPPORT

- In all cases, the vendor shall immediately provide highly technical personnel to service all the equipment including its components/peripherals whenever hardware breakdown and/or any related problem should occur.
- On call support shall be available during working hours, one (1) hour response from time of the call (through telephone call) shall be provided.
- On-site support must have a response time of not more than 6 hours from the time of the call in cases when the phone support could not solve the problem