

TERMS OF REFERENCE AND TECHNICAL SPECIFICATION

FOR THE PROCUREMENT OF AIRCONDITIONING UNITS FOR NFTI

Camp Vicente Lim

A. GENERAL SPECIFICATIONS

	OFFICE EQUIPMENT	MINIMUM REQUIREMENTS
1	AIRCONDITIONER 30 UNITS	2HP ,Inverter ,Window Type, Single Phase, 230 V, Remote Controlled with installation Specifications: Inverter type, high cooling performance, anti-rust design, strong and robust casing materials.

B.DELIVERABLES

B.1 WARRANTY

The Air-conditioning units shall be covered by warranty on all parts, components and after sales services for a period of one (1) year after its inspection and acceptance by the Procuring Entity.

B.2 DOCUMENTATION

1. To be included in the Technical Bid Documents
 - 1.1 Brochures showing the specifications of the product being offered.
2. Submission of Warranty Certificate.

C. INSPECTION AND TESTS

The Philippine Public Safety College (PPSC) shall have the right to inspect and/or test the goods to confirm conformity with the contract. The winning bidder shall furnish test equipment, instrumentation, personnel and supplies necessary to perform all testing. PPSC shall be given a five (5) working day notice prior to tests.

D. MAINTENANCE/TECHNICAL SUPPORT


- During the warranty period, the vendor shall provide highly technical personnel to service all the equipment including its components/peripherals whenever hardware breakdown and/or any related problem should occur.
- To conduct cleaning of filter on the 4th and 8th month of warranty period.
- On call support shall be available 24 hours a day, 7 days a week. A one (1) hour response from time of the call (through telephone call) shall be provided.

- On hardware repair, testing shall be done on-site to know the extent of the problem. All components beyond repair shall be replaced at no cost during the warranty period. Service units should be available for the system and peripherals a day after testing and diagnosis for replacement of the defective unit(s).
- The winning bidder must provide expert personnel to service the equipment whenever any related problem should occur.

E. AVAILABILITY

- The winning bidder must provide pro-active maintenance support that automatically generates reports and ends notification to the manufacturers 24/7 call support centers in cases of system abnormality so that component will be replaced and errors will be fixed before failure occurs.
- Hardware components that cannot be repaired must be provided with a service unit and/or replacement parts must be available at all times
- The component(s) that has been replaced must be operational within four (4) hours including response time of two (2) hours.


Prepared by:


 Engr. Ulysses R. Malapitan
 Admin Asst. 1, Eng'g. Unit, GSS,AD

Reviewed By:


 Engr. Romy V. Yalo
 Acting Chief, GSS,AD


Submitted By:


 PCOL Froilan P. Elope
 Acting Chief, Administrative Division

Recommending Approval


 PBGen. Ferdinando G. Sevilla
 VP for Administration

Approved By:


PDDG Ricardo F. De Leon Ph. D.
 President, PPSC