

TERMS OF REFERENCE AND TECHNICAL SPECIFICATION

FOR THE PROCUREMENT OF AIRCONDITIONING UNITS FOR NFTI

Camp Vicente Lim

A. GENERAL SPECIFICATIONS

	OFFICE EQUIPMENT	MINIMUM REQUIREMENTS
1	AIRCONDITIONER 30 UNITS	2HP ,Inverter ,Window Type, Single Phase, 230 V, Remote Controlled with installation Specifications: Inverter type, high cooling performance, anti-rust design, strong and robust casing materials.

B.DELIVERABLES

B.1 WARRANTY

The Air-conditioning units shall be covered by warranty on all parts, components and after sales services for a period of one (1) year after its inspection and acceptance by the Procuring Entity.

B.2 DOCUMENTATION

1. To be included in the Technical Bid Documents
 - 1.1 Brochures showing the specifications of the product being offered.
2. Submission of Warranty Certificate.

C. INSPECTION AND TESTS

The Philippine Public Safety College (PPSC) shall have the right to inspect and/or test the goods to confirm conformity with the contract. The winning bidder shall furnish test equipment, instrumentation, personnel and supplies necessary to perform all testing. PPSC shall be given a five (5) working day notice prior to tests.

D. MAINTENANCE/TECHNICAL SUPPORT

- During the warranty period, the vendor shall provide highly technical personnel to service all the equipment including its components/peripherals whenever hardware breakdown and/or any related problem should occur.
- To conduct cleaning of filter on the 4th and 8th month of warranty period.
- On call support shall be available 24 hours a day, 7 days a week. A one (1) hour response from time of the call (through telephone call) shall be provided.