

TECHNICAL SPECIFICATIONS

FOR THE PROCUREMENT AND INSTALLATION OF GENERATORS AT PPSC HEAD OFFICE AND NPC -SILANG

| OFFICE EQUIPMENT | Minimum Requirements |
|-------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Diesel Generator | <p>a. PPSC HEAD OFFICE (2 units)</p> <ul style="list-style-type: none">• Packaged Diesel Engine GENSET• Turbocharged rated at 64KW/80KVA Standby Rated 1800RPM, 60 Hertz, 3 phase, 0.8 Power Factor• 400 volts convertible 230 volts or 230 volts convertible to 400 volts, 3 phase complete with standard accessories. <p>b. NPC-SILANG (2 units)</p> <ul style="list-style-type: none">• Packaged Diesel Engine GENSET• Turbocharged rated at 64KW/80KVA Standby Rated 1800RPM, 60 Hertz, 3 phase, 0.8 Power Factor• 230 volts, 3 phase complete with standard accessories. |

TERMS OF REFERENCE

PROCUREMENT AND INSTALLATION OF GENERATOR SET AND ACCESSORIES FOR THE PHILIPPINE PUBLIC SAFETY COLLEGE (PPSC) HEAD OFFICE AND NATIONAL POLICE COLLEGE (NPC)-SILANG

A. Background

The Philippine Public Safety College is government agency established pursuant to RA 6975 as amended by RA 11279 and attached agency of the Department of the Interior and Local Government in compliance with Republic Act. No. 9184 known as the "Government Procurement Reform Act". The Philippine Public Safety College Central Office will be conducting a public bidding for the **SUPPLY, INSTALLATION AND COMMISSIONING OF FOUR (4) UNITS BRAND NEW GENERATOR SET (GENSET)**. Two (2) units for PPSC Head Office and two (2) units at National Police College (NPC)-Silang.

B. Objective

The new GENSET is to be installed and delivered at the newly constructed PPSC Office Building at MWSS Compound cor. Ayala Heights Old Balara Quezon City in order to provide continuous services to PPSC HO valued clientele in case of power outage and at the National Police College (NPC), Silang Cavite.

C. Approved Budget for the Contract

The Approved Budget for the Contract (ABC) is Three Million Four Hundred Thousand Pesos (P3,400,000.00), inclusive of all applicable taxes, insurances/bonds, permits, licenses and/or other miscellaneous expenses and cost on the required civil and mechanical works as well as inclusive of electrical installation/cabling within the office building premises of PPSC Head Office and